



NOTES:

1. BOX SHOULD BE LOCATED NEAR A STATIONARY OBJECT, SUCH AS A STREET LIGHT FOR PROTECTION, OR PLACE SUFFICIENT CONCRETE AROUND RISER OR BELOW GROUND.
2. LOCATIONS AND NUMBERS OF SAMPLING POINT WILL BE DESIGNATED BY THE CITY OF CHINO HILLS IN ACCORDANCE WITH THE REQUIREMENTS OF CALIFORNIA ADMINISTRATIVE CODE TITLE 22 DEPARTMENT OF HEALTH.

AUGUST 2005

CITY OF CHINO HILLS			
Revised: / /	by:	Approved by:	
Revised: / /	by:		
Revised: / /	by:	CITY ENGINEER	

**WATER QUALITY
SAMPLING STATION**

W-17

LIST OF MATERIAL

ITEM	DESCRIPTION	FORD	JONES	MUELLER	REMARKS
①	BALL ANGLE METER STOP, 1"	BA23-444W	J-1963 W	B-24258	
②	BALL VALVE, 1"	—	J-1908	—	
③	COUPLING COMPRESSION FITTING, 1"	—	J-2607	—	
④	1/2" X 3/8" STAINLESS STEEL BALL VALVE	—	—	—	"KORALEEN" OR APPROVED EQUAL
⑤	1/2" IPT X 1" PJCTS ADAPTER	94-13	—	—	OR APPROVED EQUAL
⑥	METER BOX	—	—	—	SEE PART 3 SEC. 2-9

AUGUST 2005

CITY OF CHIND HILLS			WATER QUALITY SAMPLING STATION	W-17
Revised: / /	by:	Approved by:		
Revised: / /	by:			
Revised: / /	by:	CITY ENGINEER		