



**NOTES:**

1. LOCATION OF WATER LINES AND VALVES SHALL BE SHOWN ON THE PLAN VIEW, FOR SUBDIVISION IMPROVEMENT PLANS. SEE HEALTH DEPARTMENT STANDARDS, SECTION 7, DISTRIBUTION SYSTEM, FOR MINIMUM DEPTH.
2. HYDRANT TO BE SET PLUMB, WITH NOZZLE A MINIMUM OF EIGHTEEN (18") INCHES ABOVE GROUND LEVEL. WHEN HYDRANTS ARE PLACED BEFORE GRADING IS COMPLETED, THE FINAL GRADE LINE AND ACCESSIBILITY SHOULD BE CONSIDERED.
3. NO OBSTRUCTION SUCH AS POLES, GUY LINES, ETC. SHOULD BE PLACED CLOSER THAN (5') FEET TO THE HYDRANT.

CITY OF CHINO HILLS		FIRE HYDRANT LOCATION	308
CHRIS VOGT CITY ENGINEER			