



NOTES:

1. 4" PIPE FOR SINGLE DWELLINGS. 6" MIN. FOR ALL OTHER LATERALS.
2. LATERAL LOCATIONS SHALL BE MEASURED AT RIGHT ANGLES TO STREET CENTERLINE FROM THE CENTERLINE OF THE NEAREST DOWNSTREAM MANHOLE COVER.
3. WHENEVER DEPTH OF COVER OVER LATERAL IS LESS THAN 4'-0", SPECIAL BEDDING OR CONCRETE CRADLE PER STANDARD DRAWING NO. S-3 SHALL BE USED.
4. CONTRACTOR SHALL REFERENCE EACH LATERAL WITH AN "S" MARK ON THE CURB FACE.

AUGUST 2005

CITY OF CHIND HILLS		<p>SEWER LATERAL CURBED STREETS</p>	<p>S-10</p>	
Revised: / /	by:			Approved by:
Revised: / /	by:			CITY ENGINEER